



Agnisuraksha Engineers

FIRE & SAFETY

Plot No.- 8, Shop No. - 12, Siddhivinayak Complex, Sangam Nagar, Old Sangvi, Last Bus Stop, Near Swami Narayan Temple, Pune - 411027

Ph. No. :- 7720856685 / 9767422877 | Email :- agnisurakshaengineers@gmail.com

Date :-


REF NO. AE/2020-21/2/1

DATE- 16.02.2021

To

AISSMS COLLEGE OF ENGINEERING

KENNEDY ROAD, NEAR RTO, PUNE.



SUB :- Issue of Fire Audit Report For Fire Hydrant System.

Certified that I/We have carried out inspection of the Fire Prevention and Life Safety Measures installed in the following building or premises, namely:- **AISSMS COLLEGE OF ENGINEERING**

at KENNEDY ROAD, NEAR RTO, PUNE.

I/We further certify that these installation in the above mentioned buildings are maintained in good repair and efficient conditions during the period From – 01/01/2021 To- 31/12/2021 ,as required under the provision of the Maharashtra Fire Prevention and Life Safety Measures Act ,2006 (Mah-III of 2007).The details of the inspection and maintenance of installation carried out by me /us are mentioned as below, herewith.

Place:- Pune.

Date:- 16/02/2021

Signature & Address of the

Licensed Agency

License No & Seal



A.O/ Registrar

AGNISURAKSHA ENGINEERS

Fire Hydrant System Audit Report

Name Of College- AISSMS College Of Engineering

Address- Kenndey Road, Near RTO Pune, Pune.

Date Of Inspection - 13/2/2021

Inspection By- Mr.Kiran Dhamale/Mr.Yogesh

Sr No	Fire Hydrant Point	Location	Hydrant Valve	Hydrant Cap	Hydrant Washer	Hose Cabinet	Door Glass	Hammer	Key & Glass	Hydrant Hose	Nozzal	Flow of water check	MCP	Hooter	Remark
1	HP 1	4th Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
2	HP 2	4th Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
3	HP 3	3Rd Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
4	HP 4	3Rd Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
5	HP 5	2nd Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
6	HP 6	2nd Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Look Lug -1 No Required
7	HP 7	1st Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
8	HP 8	1st Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
9	HP 9	GD Floor	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	Ok	
10	HP 10	GD Floor	Ok	Ok	Ok	Ok	Ok	Ok	NO	Ok	Ok	Ok	Ok	Ok	Key & Glass-1 No Required

Fire Extinguisher Check Points

SR No	Type	Capacity	Total Nos	Status
1	ABC	1KG	16	OK
2	ABC	2 KG	80	OK
3	ABC	5KG	12	OK
4	MF	9LTR	3	OK
		Total	111	

1) Booster Pump 20HP - Manual Start / Stop Type, Flow Of Water Check - Ok.

2) Fire Alarm Panel, Manual Call Points & Hooter Check -Ok.

Audit Points-

1) Need To Installed Co2 Type 4.5KG -2 No Fire Extinguisher at DG Room & Electrical Room.

2) Need To Installed Fire Exit & Assbly Point Bord At all Floor.

Stamp

For Agnisuraksha Engineers,

ph 020 27284786

Authorised Signatory.

Kiran Dhamale-9767422877

FORM-N

(see section 9(3) and rule 14)

License to act as Licensed Agency for the
purpose of Fire Prevention And
Life Safety Measures

Licence No. MFS-LA/ 2020/RF-169
2020/RD-150

Date: 24-08-2021

Licence is hereby granted / renewed under the
provisions of sub-section (3) of section 9 of the Maharashtra
Fire Prevention and Life Safety Measures Act, 2006 (Mah. III
of 2007) to M/s. Agni-Suraksha Engineers

having their registered office at 55/6/2, Khande,
Nagpur, Pimpale G. P. Road, New Sangvi,
Pune-411027. to act as a

Licensed Agency for the purpose of the said Act for
execution of the Fire Prevention and Life Safety
Measures in relation to -

- 1) Fire Fighting System installation such as hydrants,
sprinklers, pumping, etc. in - class A+B/C/D
- 2) Detection and Fire suppression system in-class A+B/C/D
- 3) Passive protection - such as - cable protection, fire
doors, etc. in-class A+B/C/D

Subject to the provisions of sub-section (4) of section 9
of the said Act and rule 14 of the Maharashtra Fire
Prevention and Life Safety Measures Rule, 2009, the licence
will be valid for a Period from 24.08.2020 to
23.08.2021

महाराष्ट्र शासन

महाराष्ट्र अग्निशमन सेवा संचालनालय

विधानगरी, हंस भुगा मार्ग,

सांताक्रुझ (पूर्व), मुंबई - ४०० ०९८.

टेलि.नं. २६६७ ७५५५, फॅक्स नं. २६६७ ७६६६.

www.mahafireservice.gov.in

(डॉ. प्र. सु. रहांगदळे)

संचालक

महाराष्ट्र अग्निशमन सेवा

For - AFSMS College
of Engineering.
Kennedy Road, RTO.
Pune.

नमूना - न

(कलम ९(३) व नियम १४ पहा)

आग प्रतिबंधक व जीवसंरक्षक उपाययोजनांच्या
प्रयोजनार्थ लायसन्सप्राप्त अभिकरण म्हणून
काम करण्याकरिता लायसन्स

लायसन्स क्रमांक : मअसे-लाअ/ २०२०/३३/१५५६-७६९
दिनांक : २४.०८.२०२०.

महाराष्ट्र आग प्रतिबंधक व जीवसंरक्षक उपाययोजना अधिनियम,
२००६ (२००७ चा मंदा. ३) याच्या कलम ९ च्या पोट-कलम (३) च्या
तरतुदीनुसार स्थानिक प्राधिकरण / नियोजनप्राधिकरण क्षेत्रात-

- १) हायड्रंट, स्ट्रिंकलर्स, पंपिंग इ.सह अग्निशमन यंत्रणा
बसविणे, - वर्ग अ+ब / क / ड
- २) आग शोधक आणि आग निष्प्रभावित करण्याची व्यवस्था,
(Detection and fire suppression) - वर्ग अ+ब / क / ड
- ३) स्थानीय संरक्षण (Passive protection) - कॅबल-संरक्षण,
(cable protection), अग्निशमनदरवाजे, (fire doors).

- वर्ग अ+ब / क / ड

इत्यादी सारखी अग्निशमन व्यवस्था बसविण्याशी संबंधित आग
प्रतिबंधक व जीवसंरक्षक उपाययोजनांची अंमलबजावणी करण्याकरिता
उक्त अधिनियमाच्या प्रयोजनार्थ लायसन्स प्राप्त अभिकरण म्हणून काम
करण्याकरिता, याद्वारे ४५/६/२, के.एन. रोड, रंगवी,
पिंपळी, पुणे, ४११०२७, या ठिकाणी, पुणे, ४११०२७.

येथी नोंदणीकृत कार्यालय असलेल्या मे.अग्नि-सुरक्षा इंजिनिअर्स
यांना लायसन्स देण्यास येत आहे / लायसन्सचे नूतनीकरण करून देण्यात
येत आहे.

हे लायसन्स उक्त अधिनियमाच्या कलम ९ च्या पोट-कलम (४) च्या
आणि महाराष्ट्र आग प्रतिबंधक व जीवसंरक्षक उपाययोजना नियम, २००९
याच्या नियम १४ च्या तरतुदीच्या अधीन राहून, दिनांक २४.०८.२०२०
पासून दिनांक २३.०८.२०२१ पर्यंत या कालवधीकरीता वैध राहील.